

# Project Details

Design Code: AISC 360-10 ASD  
 Provision: ASD  
 Country: United States



User Name: Sam  
 Project Name: Structure  
 Project ID: 21722  
 Company: XYZ Co.  
 Designer: Sam Carigliano  
 Client: ABC Inc.  
 Unit System: Imperial

NOTE: The calculations for this design code are in **BETA** stage development. If you notice any irregularities or problems please contact support@skyciv.com.

## Design Input Information

Design Factors			
$\Omega_t$	$\Omega_c$	$\Omega_b$	$\Omega_v$
1.67	1.67	1.67	1.67

Design Materials			
ID	E (ksi)	Fy (ksi)	Fu (ksi)
1	29000	38	60

Section Dimensions					
ID	Name	d (in)	tw (in)	bf (in)	tf (in)
1	W12x65	1.210e+1	3.900e-1	1.200e+1	6.050e-1

ID	Name	d (in)	bf (in)	tw (in)	
2	HSS20x8x1/2	2.000e+1	8.000e+0	4.650e-1	

Section Properties								
ID	Name	A (in <sup>2</sup> )	J (in <sup>4</sup> )	I <sub>yp</sub> (in <sup>4</sup> )	I <sub>zp</sub> (in <sup>4</sup> )	I <sub>w</sub> (in <sup>6</sup> )	S <sub>yp</sub> (in <sup>3</sup> )	S <sub>zp</sub> (in <sup>3</sup> )
1	W12x65	1.9100e+1	2.1800e+0	1.7400e+2	5.3300e+2	5.7800e+3	4.4100e+1	9.6800e+1
2	HSS20x8x1/2	2.4600e+1	7.5700e+2	2.8300e+2	1.1900e+3	0.0000e+0	7.9500e+1	1.5200e+2

Member Properties							
Member ID	Section ID	KzL (ft)	KyL (ft)	Cb	LST	LSC	LD
1	1	20	20	2.22,2.20,2.20,2.20,2.20,2.20,2.20,2.20,2.20,2.20,2.15,2.15	300	200	250
2	1	20	20	2.22,2.22,2.22,2.22,2.22,2.22,2.22,2.22,2.22,2.22,2.22	300	200	250
3	1	20	20	2.22,2.22,2.22,2.22,2.22,2.22,2.22,2.22,2.22,2.23,2.23	300	200	250
4	1	20	20	2.22,2.19,2.19,2.19,2.19,2.19,2.19,2.19,2.19,2.15,2.15	300	200	250
5	1	15	15	1.97,1.93,1.93,1.93,1.93,1.93,1.93,1.93,1.93,1.85,1.85	300	200	250
6	1	15	15	1.98,1.96,1.96,1.96,1.96,1.96,1.96,1.96,1.96,1.92,1.92	300	200	250
7	1	10	10	3.17,3.12,3.12,3.12,3.12,3.12,3.12,3.12,3.12,3.04,3.04	300	200	250
8	1	10	10	3.16,3.11,3.11,3.11,3.11,3.11,3.11,3.11,3.11,3.02,3.02	300	200	250
9	1	20.6155	20.6155	1.83,1.86,1.86,1.86,1.86,1.86,1.86,1.86,1.86,1.92,1.92	300	200	250
10	1	20.6155	20.6155	1.82,1.85,1.85,1.85,1.85,1.85,1.85,1.85,1.85,1.90,1.90	300	200	250
11	2	20	20	-	300	200	250
12	2	20	20	-	300	200	250
13	2	20	20	-	300	200	250

## Member Design Capacity

Member ID	$P_n/\Omega_t$ (kip)	$P_n/\Omega_c$ (kip)	$M_{zn}/\Omega_b$ (k-ft)	$M_{yn}/\Omega_b$ (k-ft)	$V_{yn}/\Omega_v$ (kip)	$V_{zn}/\Omega_v$ (kip)
1	434.61	305.85	183.55	83.62	71.73	198.24
2	434.61	305.85	183.55	83.62	71.73	198.24
3	434.61	305.85	183.55	83.62	71.73	198.24
4	434.61	305.85	183.55	83.62	71.73	198.24
5	434.61	356.67	183.55	83.62	71.73	198.24
6	434.61	356.67	183.55	83.62	71.73	198.24
7	434.61	398.06	183.55	83.62	71.73	198.24
8	434.61	398.06	183.55	83.62	71.73	198.24
9	434.61	299.21	183.55	83.62	71.73	198.24
10	434.61	299.21	183.55	83.62	71.73	198.24
11	559.76	419.02	288.22	61.88	236.23	83.86
12	559.76	419.02	288.22	61.88	236.23	83.86
13	559.76	419.02	288.22	61.88	236.23	83.86

## Design Ratio

Member ID	P	Mz	My	Vy	Vz	(P,Mz,My)	KL/r	$\delta$	Status
1	0.02	0.00	0.08	0.00	0.00	0.09	0.40	0.00	OK
2	0.02	0.01	0.03	0.00	0.00	0.04	0.40	0.00	OK
3	0.02	0.01	0.03	0.00	0.00	0.04	0.40	0.00	OK
4	0.02	0.00	0.08	0.00	0.00	0.09	0.40	0.00	OK
5	0.01	0.01	0.03	0.00	0.00	0.04	0.30	0.00	OK
6	0.01	0.01	0.03	0.00	0.00	0.04	0.30	0.00	OK
7	0.00	0.01	0.01	0.01	0.00	0.02	0.20	0.00	OK
8	0.00	0.01	0.01	0.01	0.00	0.02	0.20	0.00	OK
9	0.00	0.02	0.01	0.01	0.00	0.02	0.27	0.01	OK
10	0.00	0.02	0.01	0.01	0.00	0.02	0.27	0.01	OK
11	0.00	0.00	0.19	0.00	0.05	0.19	0.35	0.00	OK
12	0.00	0.00	0.06	0.00	0.01	0.07	0.35	0.00	OK
13	0.00	0.00	0.06	0.00	0.01	0.06	0.35	0.00	OK

## Definitions

$\Omega_t$	Safety factor for tensile
$\Omega_c$	Safety factor for compression
$\Omega_b$	Safety factor for flexure
$\Omega_v$	Safety factor for shear
E	Modulus of elasticity
$F_y$	Specified minimum yield stress
$F_u$	Specified minimum tensile strength
A	Cross-sectional area
J	Torsional constant
$I_{yp}$	Moment of inertia about the Y axes
$I_{zp}$	Moment of inertia about the Z axes
I <sub>w</sub>	Warping constant
$S_{yp}$	Plastic section modulus about the Y axis
$S_{zp}$	Plastic section modulus about the Z axis
KL	Effective length
$C_b$	Buckling modification factor (from all load combinations)
L <sub>b</sub>	Length between braced points
LST	Limited slenderness for tension
LSC	Limited slenderness for compression
LD	Limited deflection
$P_n$	Nominal axial strength (tension/compression)
$M_n$	Nominal flexural strength (about Z/Y axis)
$V_n$	Nominal shear strength (along Z/Y axis)
P	Design ratio in case of axial force
Mz	Design ratio in case of bending about Z axis
My	Design ratio in case of bending about Y axis
Vy	Design ratio in case of shear along Y axis
Vz	Design ratio in case of shear along Z axis
(P,Mz,My)	Design ratio in case of axial force and bending action
KL/r	Design ratio in case of section slenderness
$\delta$	Design ratio in case of member deflection
OK	Capacity is provided
NG	Capacity is not provided